

## HINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312304001041

**Applicant** 

Newson Gale Limited

Address

Omega House, Private Road 8, Colwick, Nottingham NG4 2JX, UK

Manufacturer

Newson Gale Limited

Address

Omega House, Private Road 8, Colwick, Nottingham NG4 2JX, UK

**Production Factory** 

Newson Gale Limited

**Production Address** 

Omega House, Private Road 8, Colwick, Nottingham NG4 2JX, UK

Product

Earth-Rite ER II

Model/Type

See annex

Ex marking

Ex ec [ia Ga] nC IIC T4 Gc, Ex tb [ia Da] IIIC T70°C Db

Reference Standards

GB/T3836.1-2021, GB/T3836.3-2021, GB/T3836.4-2021,

GB/T3836.8-2021, GB/T3836.31-2021

Certification mode

Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product and CNEX-C2301-2019 Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product.

See Annex for the detailed product information (2 pages).

Initial issue date: 2021-05-11

Issued date: 2023-04-29

Valid to: 2026-05-10

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.



Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.



http://www.ccc-cnex.com ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China

Tel: 0377-63239734

P.C.: 473008



## CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312304001041

Page 1 of 2

## Product information:

1. This certificate covers the following models:

- Detailed models refer to the following table:

Product code	Mounting	Power supply	Monitoring unit board	
PLUSP1EA*	terrestrial	a.c.	single mode	
PLUSP1ED*	mobile or terrestrial	d.c.	single mode tri mode	
RTRP1EA*	terrestrial	a.c.		
MGVP1ED*	mobile	d.c.	tri mode	
RTRP1ED*	terrestrial	d.c.	tri mode	
FIBCP1EA*	terrestrial	a.c.	single mode	
FIBCP1ED*	terrestrial	d.c.	single mode	

<sup>\*:</sup> none or S, S:Optional Intrinsically Safe switching PCB which is used to switch an external intrinsically safe circuits or signals.

The installation must be in accordance with the relevant control drawing ERII-Q-10174 Al. The maximum input voltage (Um) is 250 V for all versions. The single mode version provides resistive-only monitoring. The tri-mode version provides capacitive and resistive monitoring. The safety description at the intrinsically safe output of the ER II depends on the version:

appointe on the ve	101011.		
RTRP1EA, RTRP1ED & MGVP1ED		PLUSP1EA &	FIBCP1EA &
models		PLUSP1ED models	FIBCP1ED models
Tri-mode IS	Tri-mode IS output		Single mode IS
output at	at PL2	output at PL3/PL4	output at PL3/PL4
PL3/PL4			
Uo = 8.61 V	Simple apparatus	Uo = 8.61 V	Uo = 8.61 V
lo = 60 mA	only	lo = 41 mA	lo = 0.87 mA
Po = 129 mW		Po = 88 mW	Po = 8 mW
Co = 1.0 µF		Co = 0.361 µF	Co = 5.9 µF
Lo = 9.8 mH		Lo = 21 mH	Lo = 46 H

For all models, intrinsic safety is maintained if the cable connected to any intrinsically

Issued date: 2023-04-29

Director





Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



http://www.ccc-cnex.com ccc.china-ex.com Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008

Tel: 0377-63239734

Email: ccc@cn-ex.com



## CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312304001041

Page 2 of 2

safe output terminal does not exceed 100m.

Optional Intrinsically Safe switching PCB which is used to switch an external intrinsically safe circuits or signals with the following I.S parameters:

Optional IS Switching PCB Terminal PL1 Ui = 30V, Ii = 500mA, Ci = 0, Li = 0

01 00 V, II = 000111A, OI =

IP Degree: IP66

Ex marking: Ex ec [ia Ga] nC IIC T4 Gc, Ex tb [ia Da] IIIC T70°C Db

- Producers should organize production in accordance with the technical documents approved by the certification body.
- 2. Specific conditions of safety use:
  - Rated ambient temperature range: -40 °C ~+55 °C.
  - In locations where high external humidity and internal temperature variations (e.g. frequent on-off cycles) may cause condensation inside the equipment, the interior shall be periodically inspected.
  - See instruction for other information.
- Certificate related report(s):
  - Type test report: CQST2011C087, CQST2011C087/01
  - Factory inspection report: CN2023Q030172
- Certificate change information:
  - 1st change on April 29, 2023:

Updated the standards for certification.

Issued date: 2023-04-29

Director:

一番大玉



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.

